



# Certificate / Certificat Zertifikat / 合格証

ROT 1803043 C001

exida hereby confirms that the:

## EHF - Self Contained Electro-Hydraulic Actuators

### Rotex Manufacturers & Engineers Pvt. Ltd., Maharashtra - India

Have been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

#### Safety Function:

The FSE Actuator will move the attached Valve to the designed safe position per the Actuator design within the specified safety time when the ESD Solenoid is De-Energized.

#### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer  
may use the mark:



Revision 3.0 March 16, 2022  
Surveillance Audit Due  
December 1, 2024



Evaluating Assessor

Certifying Assessor

ROT 1803043 C001

**Systematic Capability: SC 3 (SIL 3 Capable)****Random Capability: Type A, Route 2<sub>H</sub> Device****PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application****Systematic Capability :**

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2<sub>H</sub>.

**IEC61508 Failure Rates in FIT<sup>1</sup>**

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
EHF ESD Function Fail Safe on Loss of Power configuration	0	2691	0	528
EHF ESD Function Stay Put on Loss of Power configuration	0	1082	0	528

<sup>1</sup>FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** ROT 18/03-043 R002 V3R1 (or later)

**Safety Manual:** RTX-EHF-18-04 Rev 3 (or later)



80 N Main St  
Sellersville, PA 18960